

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/06/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155675		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED 08/04/2015	
NAME OF PROVIDER OR SUPPLIER MORNING BREEZE RETIREMENT COMMUNITY AND HEALTHCARE				STREET ADDRESS, CITY, STATE, ZIP CODE 950 N LAKEVIEW DR GREENSBURG, IN 47240			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 08/04/15</p> <p>Facility Number: 011039 Provider Number: 155675 AIM Number: 200299100</p> <p>At this Life Safety Code survey, Morning Breeze Retirement Community and Healthcare was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and hard wired smoke detectors in all resident sleeping rooms. The healthcare portion of the facility has a capacity of 56 and had a census of 54 at the time of this visit.</p> <p>All areas where residents have customary access were sprinkled and all areas providing facility services were sprinkled. The facility has a detached wooden maintenance workshop building and two wooden storage sheds which was not sprinkled.</p>			K 000			
K 000	INITIAL COMMENTS			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/06/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155675	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED 08/04/2015
NAME OF PROVIDER OR SUPPLIER MORNING BREEZE RETIREMENT COMMUNITY AND HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 950 N LAKEVIEW DR GREENSBURG, IN 47240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 08/04/15</p> <p>Facility Number: 011039 Provider Number: 155675 AIM Number: 200299100</p> <p>At this Life Safety Code survey, Morning Breeze Retirement Community and Healthcare was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2 for the Center Hall 2015 bed addition, resident rooms 1, 2, 3 and 4.</p> <p>This one story facility was determined to be of Type V (111) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and hard wired smoke detectors in all resident sleeping rooms. The healthcare portion of the facility has a capacity of 56 and had a census of 54 at the time of this visit.</p> <p>All areas where residents have customary access were sprinkled and all areas providing facility services were sprinkled. The facility has a detached wooden maintenance workshop building and two wooden storage sheds which was not sprinkled.</p>	K 000			